

Addendum 001

Monday, 04/15/2024

AMP3: 29 HVAC Replacement Project
Capital Fund Program
Wilson Housing Authority

1. Wilson Housing Authority request that all HVAC piping be double wall.
2. Wilson housing Authority request that the contractor calculate for proper fresh air per NC/City of Wilson inspection code.