

Addendum 002

Wednesday, 04/17/2024

AMP3: 29 HVAC Replacement Project
Capital Fund Program
Wilson Housing Authority

1. The gas furnaces are 70,000 BTU with 80% Efficiency/Flu
2. Please respond to the email saying you received the email with addendum 002